

UL Product iQ™



FTAQ.E328172 - GAS AND VAPOR DETECTOR AND SENSOR ACCESSORIES

Gas and Vapor Detector and Sensor Accessories

See General Information for Gas and Vapor Detector and Sensor Accessories

HSI FIRE & SAFETY GROUP L L C

E328172

107 GARLISCH DR

ELK GROVE VILLAGE, IL 60007-1322 USA

Aerosol tester spray, CO Check Model HO-CO2. For carbon monoxide entry and alarm actuation per NFPA72, paragraph 14.4.2.2-14H. Not for a sensitivity check. May be used alone or in conjunction with a Certified (FTAQ) Model VT-ED8 or VT-ED16 test kit consisting of a Certified (FTAQ) Model HO-VT1-aerosol dispenser head and Model HO-VP8 or HO-VP16 extension pole.

Last Updated on 2010-10-05

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"