



FTAQ.S3753 - GAS AND VAPOR DETECTOR AND SENSOR ACCESSORIES

Gas and Vapor Detector and Sensor Accessories

See General Information for Gas and Vapor Detector and Sensor Accessories

HSI FIRE & SAFETY GROUP L L C

S3753

107 GARLISCH DR

ELK GROVE VILLAGE, IL 60007-1322 USA

Carbon monoxide detector testers. Versa-Tools Models HO-VT1, HO-VP8, HO-VP16, VT-ED8 and VT-ED16 for use with Certified (FTAQ) carbon monoxide detector tester spray model HO-CO2. Model CatKit carbon monoxide test kit. For carbon monoxide entry and alarm actuation per NFPA72, paragraph 14.4.2.2-14H. Not for a sensitivity check. Models HO-VT1, HO-VP8, HO-VP16, VT-ED8 and VT-ED16 are primary Listed (URRQ) for use with Listed (URRQ) smoke detector spray models 25S and 66E. Model VT-ED8 is a kit consisting of Model HO-VT1 and Model HO-VP8. Model VT-ED16 is a kit consisting of Model HO-VT1 and HO-VP16.

Last Updated on 2013-01-11

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"