



UQKE.S7019 - HEAT-AUTOMATIC FIRE DETECTOR ACCESSORIES

Heat-automatic Fire Detector Accessories

See General Information for Heat-automatic Fire Detector Accessories

HSI FIRE & SAFETY GROUP L L C

S7019

107 GARLISCH DR

ELK GROVE VILLAGE, IL 60007-1322 USA

Fire detection heat detector accessories, heat detector tester, rate of rise, combination rate of rise/fixed temperature or rate compensation heat detectors, Model(s) HDT-694, rated 135 F and below and/or 15 F/min and below.

Fire detection heat detector accessories, heat detector tester, rate of rise, combination rate of rise/fixed temperature or rate compensation heat detectors, Model(s) HDT-694A, rated 190 F and below and/or 15 F/min and below.

Fire detection heat detector accessories, heat detector tester, rate of rise, combination rate of rise/fixed temperature or rate compensation heat detectors, Model(s) HDT-694B, rated 190 F and below and/or 15 F/min and below.

Last Updated on 2019-02-21

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"